

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Catherine and Poncho Alcano ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 641 Beldon Way # 50 Horseshoe Bend Rd  
Reno, Nv 89503 Lots 6 and 7 [Shoshone - Indian Lands]  
 2. LOCATION E 1/4 SW 1/4 Sec 6 T 11 N/S R 21 E Douglas County  
 PERMIT NO. 35-07004 - China Springs - 7 miles So Gardnerville  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Broken green black rock		0	85	85
Multicolored volcanic sands & gravels		85	522	437
Fractured purple grey & white volcanic rock		522	600	78
T.D. 600 ft.				

8. 10" - 85" WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 596 feet

Casing record 6 5/8 inch  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1 1/2</u> feet	<u>596</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 54 feet  
 Gravel packed: Yes  No   
 Gravel packed from 54 feet to 596 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3 double  
 From 576 feet to 596 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

'89 NOV -7 110:00  
 STATE ENGINEERS OFFICE

Date started 10/2/89, 19\_\_\_\_  
 Date completed 10/16/89, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 350 feet below land surface  
 Flow 15 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc.  
 Contractor  
 Address 625 Spice Islands Dr Suite L Sparks, Nv  
 Contractor 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 10/29/89