WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32529
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15424

1. OWNER Pete Parrison Const
MAILING ADDRESS 165 Indian trails
Gardnerville NV

ADDRESS AT WELL LOCATION 1016 Sunside Drive
Gardnerville NV

2. LOCATION SE ¼ SW ¼ Sec. 10 T. 12 N/S R. 19 E/W Douglas County
PERMIT NO. 19373-02 (Issued by Water Resources) Parcel No. SIERRA RANCHOS ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN W/ GRANITE BOULDERS		0	8	8
GRANITE GREY WHITE HARD FINEGRAINED		8	70	62
FRACTURED GRANITE WITH SMALL BOULDERS		70	94	24
FRACTURED GRANITE WITH WATER IN FRACTURES	✓	94	125	31
T.D. 125 FT				

RECEIVED NOV 20 '89 STATE ENGINEERS OFFICE

Date started 11-2, 1989
Date completed 11-10, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
developed with 250 psi air blew 25 GPM from 110 ft for 2 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½ to 250 inches Total depth 125 feet
9 7/8 inches
inches
Casing record 6 5/8" STEEL
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Conductor
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 125 feet

Perforations:
Type perforation Factory mill slot
Size perforation 3/32 x 3"
From 110 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 57 feet below land surface
Flow 25 G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A-1 Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1492
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11/13/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627