WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32545
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12475

1. OWNER Dana Chabot-Fency
MAILING ADDRESS 5959 Sledge
Carson City, NV

ADDRESS AT WELL LOCATION 5959 Sledge
Carson City, NV

2. LOCATION SW ¼ of ¼ Sec. 23 T. 15 N/S R. 20 E Carson City County
PERMIT NO. City 1149-1 (Issued by Water Resources) | Parcel No. | Pinion Hills (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Scale, Cuttings		150	153	3
Brown Sandstone w/ fracture bearing water Main fractures from 162-180	✓	153	180	27
Note: 6 5/8" liner extend 10 ft inside of outer casing, 8 5/8"				

STATE ENGINEER'S OFFICE
NOV 20 '89 AM 11:14

Date started Nov 16, 19 89
Date completed Nov 17, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Landed casing & blew well with 250-450 air to develop blew 60+ gpm for 1hr from 150'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 7 7/8 inches Total depth 180 feet
..... inches
..... inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	140 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal Unknown feet
Gravel packed: Yes ☐ No ☐
Gravel packed from Unknown feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 160 feet to 180 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 137 feet below land surface
Flow 60+ G.P.M. ..... P.S.I.
Water temperature 108 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 29295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Nov 17, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627