WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 32559
Permit No.
Basin 8-102

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER American Mobile Homes ADDRESS 700 Smithridge Dr. Reno Nev. 89502
Parcel # 17-302-05
2. LOCATION NW ¼ NW ¼ Sec. 18 T. 17 N/S R. 25 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Sand To Coarse Sand		0	70	70
Fine To coars Brown Sand	X	70	130	60
No Clay at all				

RECEIVED '89 NOV -7 A10:01 STATE ENGINEERS OFFICE

Date started 11-2, 1989
Date completed 11-3, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 18 Draw down 5 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 130 feet
Casing record 6 5/8 O.D.
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	+ 1 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 130 feet

Perforations:
Type perforation Mill
Size perforation 3/16 X 3
From 120 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 Feet below land surface
Flow G.P.M.
Water temperature Cold F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.C.E. Drilling & Dev.
Address P.O. Box 668 Silver Springs Nev. 89429
Nevada contractor's license number 14299
Nevada driller's license number 726
Signed H. L. Legg
Date 11-6-89

USE ADDITIONAL SHEETS IF NECESSARY

5471