WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32560
Permit No.
Basin 87.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9225

1. OWNER Dr. MARC HESCHEFF
MAILING ADDRESS 627 Rock Blvd.
Sparks, NV 89431

ADDRESS AT WELL LOCATION 8585 Dierenger Drive
Reno, NV 89511

2. LOCATION SW ¼ SE ¼ Sec. 1 T 18N N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. SW Reno (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil w/bolders		0	2	2
Sand gravel & bolders		2	8	6
Sandy clay w/sand streaks		8	15	7
Sandy clay w/some gravel		15	24	9
Soft sandy clay		24	36	12
Sandy clay		36	41	5
Clay, sand & gravel		41	60	19
Sand w/clay streaks		60	74	14
Bolders & gravel		74	88	14
Sand		88	94	6
Clay, sand & gravel		94	102	8
Sand (fine)		102	108	6
Clay, sand & gravel		108	123	15
Sand & gravel	X	123	130	7
Clay		130	149	19
Soft zone, clay		149	153	4
Clay w/sand streaks		153	157	4
Sand & small gravel	X	157	172	15
Clay		172 & on		
Stoped at 173 ft.				

NOV 29 '89 A9:21 STATE ENGINEER'S OFFICE

Date started 11-21-89, 19
Date completed 11-22-89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 173 feet
inches
inches
Casing record 173' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	173 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 173 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 109 feet to 169 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8 feet below land surface
Flow 50+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 25, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627