

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 10930

1. OWNER JIM SALIM (Q & D CONSTR.) ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2240 Schooner Cir. 445 Anitra Drive _____
Reno, NV 89509 Reno, NV 89511 _____

2. LOCATION SE 1/4 NW 1/4 Sec. 2 T. 18N N/S R. 19 E Washoe County
 PERMIT NO. 41-290-1720 SW Reno
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil w/some volcanic bolders		0	1	1
Volcanic mud flow w/some bigger bolders		1	30	29
Gray volcanic rock		30	41	11
Brown volcanic rock		41	202	161
Light brown volcanic rock		202	210	8
Yellow soft clay		210	383	173
Soft zone (app. 6-9GPM)	X	383	387	4
Purple gray volcanic rock		387	407	20
Gray volcanic rock		407	417	10
Fracture	X	417	418	1
Gray volcanic rock		418	441	23
Fracture	X	441	443	2
Gray volcanic rock		443	455	12
Fracture	X	455	459	4
Gray volcanic rock		459	465	6
Fracture	X	465	470	5
Gray volcanic rock		470	485	15
Fracture	X	485	491	6
Gray & White clay w/ gray rilite		491	500	9

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 500 feet
 _____ inches
 _____ inches
 Casing record 500' steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>500</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement grout
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 500 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 400 feet to 490 feet
 From _____ feet to _____ feet

Date started 11-6-89, 19_____
 Date completed 11-10-89, 19_____
 NOV 29 89 A 9:20

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 330 feet below land surface
 Flow 60+ G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor
 Address P.O. Bpx 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed Wayne P. Fedman By driller performing actual drilling on site or contractor
 Date November 15, 1989