WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32570
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12007

1. OWNER Sanford Johnson
MAILING ADDRESS Box 2376 Fallon, Nev 89406
ADDRESS AT WELL LOCATION 10 mile S.E. Fallon on Testoline Road

2. LOCATION S.W. ¼ NW ¼ Sec. 9 T. 18 N/S R. 29 E. Churchill County
PERMIT NO. ____ (Issued by Water Resources) Parcel No. ____ Subdivision Name ____

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Sand mixed with clay		10	20	10
Yellow clay		20	30	10
Tule mud thin		30	44	14
Tule mud with water		44	70	24
Green clay		70	75	5
Thick coal black		75	90	15
Tule mud come out in				
chunks like jelly				
Green clay		90	95	5
Multi colored sand with		95	100	5
" " sand coarse		100	105	5
Coarse sand & small		105	118	13
gravel up to ¼ inch				
well rounded				

RECEIVED NOV 29 '89 A9:34 STATE ENGINEER'S OFFICE

Date started 11-9, 1989
Date completed 11-22, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR LIFT	APP. 50 G.P.M.		

BAILER TEST
G.P.M. — Draw down — feet — hours
G.P.M. — Draw down — feet — hours
G.P.M. — Draw down — feet — hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 inches Total depth 118 feet
Casing record 6
Weight per foot ____ Thickness .188

Diameter	From	To
6 inches	0 feet	102 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Neat Cement
Depth of seal 90 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 90 feet to 118 feet

Perforations:
Type perforation Saw Cut
Size perforation 3/32
From 102 feet to 118 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 6 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature ____ ° F. Quality poor Stinks

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Potter Drilling Co. (Contractor)
Address P.O. Box 1815 Fallon Nev. (Contractor)
Nevada contractor's license number 20161
Nevada contractor's drillers number 1348
Nevada driller's license number 1348 (Actual Driller)
Signed Jim Potter (Contractor)
Date 11-27-89

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434