

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13031

1. OWNER Jay Farmer ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P. O. Box 12365 11970 I-80 East  
Reno, Nv 89510 Parcel 1 of Map 2072

2. LOCATION SE 1/4 SE 1/4 Sec. 9 T. 19 N/S R. 21 E Washoe County \_\_\_\_\_  
 PERMIT NO. 84-090-14 - \_\_\_\_\_

Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air/ Mud \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Broken volcanics with loose sands		0	85	85
Hard broken volcanics		85	178	93
Yellow clay		178	190	12
decomposed volcanics with yellow clay		190	210	20
Hard gray sand zones occasional fractures	X	210	300	90
Highly fractured gray sandstone	X	300	400	100
T.D. 400 feet				

8. 10" - 50" WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 396 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 5/8 inch  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>2</u> feet	<u>396</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 396 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 356 feet to 376 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 8/31/89, 19\_\_\_\_  
 Date completed 11/17/89, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop - 3 hours.			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 176 feet below land surface  
 Flow 15 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1509  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 11/20/89