

OFFICE USE ONLY
 Log No. 32585
 Permit No. _____
 Basin 7-92a

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13749

PRINT OR TYPE ONLY

1. OWNER RON BARR ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 8250 Osage Road 8350 Osage Road
Reno, NV 89506 Reno, NV 89506
 2. LOCATION SW 1/4 SW 1/4 Sec. 25 T. 21N N/S R. 18 E. Washoe County
 PERMIT NO. _____ Parcel No. _____ Subdivision Name Silver Knolls
Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown clay		1/2	35	34 1/2
Gray clay		35	46	11
Green clay		46	61	15
Soft sandy clay		61	70	9
Gray med to fine sands	X	70	83	13
Gray clay		83	86	3
Soft zone, gray sands	X	86	101	15
Light gray clay		101	107	6
Gray sands	X	107	124	17

*89 NOV 29 A 9:20
 STATE ENGINEERS & P.L.L.C.

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 124 feet
 Casing record 124' steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>124</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement grout
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 124 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around

From	To
<u>99</u> feet	<u>119</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started 11-16-89 19____
 Date completed 11-16-89 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 37 feet below land surface
 Flow 25 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. BOX 12370, Reno, NV 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources 923
 Signed Wayne Drilling, Inc.
 Date November 20, 1989