

OFFICE USE ONLY
 Log No. 32601
 Permit No. _____
 Basin. 624

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13383

1. OWNER Robert and Mary Lou Stone ADDRESS AT WELL LOCATION 4005 Ironwood
 MAILING ADDRESS 160 W. 6th. Ave 7-2-1-2
Sun Valley, Nv 89433
 2. LOCATION NE 1/4 SW 1/4 Sec. 7 T. 22 N/S R. 21 E. Washoe County
 PERMIT NO. 076-251-01 Palomino Valley Unit 5
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red yellow brown hard pan		0	4	4
Green tan yellow brown D.G.		4	73	69
Green clay green yellow brown sand some gravel		73	156	83
Green black white sands with green clay		156	369	213
Sticky green clay		369	394	25
Coarse brown white green yellow sands traces of green clay		394	440	46
Green silty clay traces of sands		440	483	43
T.D. 483'				

8. 12 1/2" -295 WELL CONSTRUCTION
 Diameter 11 inches Total depth 481 feet
 Casing record 8 inch
 Weight per foot 12.92 Thickness .156

Diameter	From	To
<u>8</u> inches	<u>+2</u> feet	<u>481</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Neat cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 481 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 320 feet to 340 feet
 From 400 feet to 420 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 10/24/89, 19____
 Date completed 10/30/89, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 120 feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
Contractor
 Address 625 Spice Islands Dr Suite L Sparks, Nv
Contractor 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller.
 Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
 Date 11/2/89