WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32626-8
Permit No. —
Basin 444 North Fork Area

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7769

1. OWNER V. C. Group
MAILING ADDRESS 255 W. Moana Ln. #105 Reno, NV 89509
ADDRESS AT WELL LOCATION KOA campground Elko, NV

2. LOCATION NE ¼ SW ¼ Sec. 6 T. 35 N S R. 57 E Elko, NV County
PERMIT NO. MO-178 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
(3) New Wells ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑ MO-
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MO #10 (32626)				
Sandy loam		0	3	3
Clay		3	4	1
Sand		4	12	8
Gravel w/water		12	18	6
Clay		18	19	1
Sand, gravel, clay	w/w	19	25	6
T.D. 25				
MO #4 (32627)				
Sandy loam		0	3	3
Clay		3	4	1
Sand		4	12	8
Sand & gravel	water	12	18	6
Very coarse gravel	w/w	18	25	7
T.D. 25				
MO #2 (32628)				
Sandy loam		0	3	3
Clay		3	4	1
Sand (loose)		4	12	8
Gravel w/water	w/w	12	18	6
Clay, sand, gravel	w/w	18	25	7
T.D. 25				

Date started 10/23, 1989
Date completed 10/30, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 25 feet
6 inches + 8" to 25 ft.
inches + 18" to 6 ft.
Casing record 2" PVC
Weight per foot 8" = .219 PVC = Thickness Sched 40

Diameter	From	To
inches	feet	feet
8" inches	+ 1½ feet	6 feet
2" PVC inches	+ 1 feet	25 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 10 ft. feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 10 feet to 25 feet

Perforations:
Type perforation Horiz cut screen
Size perforation .04
From 10.5 feet to 24.5 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 12 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality ?

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Muth Drilling Co. (Contractor)
Address 203 Pine St. 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada contractor's driller's number issued by the Division of Water Resources 632
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 11/24/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627