WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32675
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3587

1. OWNER ALVA + ELAINE THOMPSON ADDRESS AT WELL LOCATION
MAILING ADDRESS

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 21 S N/S R. 54 E. NYE County
PERMIT NO. (Issued by Water Resources) LOT 159 (Parcel No.) GREEN SADDLE RANCH (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	5	2
CLAY		5	37	32
CALICHIE		37	39	2
CLAY		39	62	23
CALICHIE	WB	62	63	1
CLAY		63	78	15
CALICHIE	WB	78	80	2
CLAY		80	85	5
CALICHIE	WB	85	86	1
CLAY		86	90	4
CALICHIE	WB	90	91	1
CLAY		91	108	17
CALICHIE	WB	108	112	4
CLAY		112	122	10
CALICHIE	WB	122	126	4
CLAY		126	137	11
CALICHIE	WB	137	140	3

RECEIVED
NOV 7 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-30, 1989
Date completed 11-3, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
..... inches
..... inches
Casing record 140' 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAWCUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 52 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H DRILLING (Contractor)
Address HCR BOX 70706 PAHRUMP NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22089
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-3-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627