WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32698
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9906

1. OWNER TEMPLE STEWART
MAILING ADDRESS 2354 GENOA ST
GENOA, NEVADA

ADDRESS AT WELL LOCATION
2354 GENOA STREET
GENOA, NEVADA

2. LOCATION SE ¼ NE ¼ Sec. 7 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. 17-081-03 (Issued by Water Resources) Parcel No. Subdivision Name NE

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Badly fractured broken gray granite, medium hard to hard		2	125	123
Decomposed granite, soft		125	150	25
Granodiorite, fractured w/ water		150	180	30
T.D. 180'				
Note 10 feet pea gravel in bottom to stop finest sand				

Date started Dec 4, 19 89
Date completed Dec 7, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with 25' - 45' air 9 hrs and pumped Blew 25-30 GPM from 165' for 2 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11¼" 50 inches Total depth 180 feet
8 ¾" inches
inches
Casing record 6 5/8" steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 180 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 130 feet below land surface
Flow 25+ G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & A Pump Co (Contractor)
Address Carson City, Nevada (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 21422
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Dec 7, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627