

OFFICE USE ONLY
 Log No. 32700
 Permit No. _____
 Basin 8A05

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10799

1. OWNER BENTLY NEVADA CORP. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS C/O KENNEDY/JENKS/CHILTON, INC. AIRPORT FACILITY
MATHATHON PLAZA, 10TH FLOOR, 303 2ND. ST., MINDEN, NV.
SAN FRANCISCO, CA. 94107
 2. LOCATION NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 6 T. 13 (N/S R. 20 E. DOUGLAS County
 PERMIT NO. Waiver/ 50651 Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE MW 23B
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dirt, silt, sand, clay & gravels		0	4	4
Large to small sands, large to small gravel		4	35	31
Clay		35	62	27
Large to small sands, large to small gravel		62	79	17
Clay		79	82	3

'89 FEB 18 A9:27 STATE ENGINEERS DISTRICT

8. WELL CONSTRUCTION
 Diameter 9-7/8 inches Total depth 80 feet
 _____ inches
 _____ inches
 Casing record 4-1/2 INCH O.D. X .120 INCH WALL
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>4</u> inches	<u>+1</u> feet	<u>80</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type neat cement
 Depth of seal 56 feet
 Gravel packed: Yes No
 Gravel packed from 57 feet to 80 feet
 Perforations:
 Type perforation 4 inch stainless steel wire wrap
 Size perforation .035 slot type 304
 From 60 feet to 80 feet
 From _____ feet to _____ feet

Date started September 28, 19 89
 Date completed October 9, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 4-1/2 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 63 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CHAS. SARGENT IRRIGATION INC.
 Address 9955 N. VIRGINIA ST., RENO, NV. 89506
 Nevada contractor's license number 21246
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1391
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1540 / 1573
 Division of Water Resources the On-Site driller
 Signed Larry McCracken
 By driller performing actual drilling on site or contractor
 Date NOVEMBER 10, 1989