WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32705
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12452

1. OWNER Greg Painter Construction
MAILING ADDRESS P.O. Box 37
Genoa, NV
ADDRESS AT WELL LOCATION 3394 Alpine View Road
Carson City, NV

2. LOCATION SE ¼ SE ¼ Sec. 11 T. 14 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 15-10301 (Parcel No.) Alpine View Estates (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay brown		0	5	5
Sandy Clay				
Sandy Clay		5	27	22
Sandy Clay				
Gravel				
Small pea				
Gravel pebble		27	63	41
Pebble clay				
Fine sand				
Small to Medium		63	77	14
Gravel with				
Fine sand &				
Clay				
Fine to Coarse		77	100	23
Sand with				
Gravel				
After 10 feet of pea gravel was				
Caving & stop bailed from Casing				
up Casing				
T.D. 100				

Date started 12-2-59, 19
Date completed 12-3-59, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Well flowing 3-4 GPM			
Well head constructed & well			
is shut in			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6" inches Total depth 100 feet
9.5 inches
inches
Casing record Galv. steel
Weight per foot 14.7 Thickness .156

Diameter	From	To
6 5/8 inches	47 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 100 feet

Perforations:
Type perforation Factory slotted
Size perforation 3/32" x 3"
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Flowing feet below land surface
Flow 3-4 G.P.M. 2 P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H&H Pump Co (Contractor)
Address Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 25695
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-4-59

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627