

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9685

1. OWNER Conrad E. Bluhm ADDRESS AT WELL LOCATION XXI
 MAILING ADDRESS P.O. Box 10121 44 Robin Rd. Yerington, NV
Eugene, Or. 97401

2. LOCATION SE 1/4 SE 1/4 Sec. 20 T 14N N/S R. 25 E Lyon County

PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 14-26-111 Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
sand & clay		3	6	3
clay & sand		6	10	4
sand & gravel fill		10	45	35
sand, gravel & clay		45	50	10
sand & rock	x	50	65	15
rock w/ sand	x	65	90	25
rock	x	90	93	3
Plugged By Well Log 125900				

8. WELL CONSTRUCTION
 Diameter 10 5/8 inches Total depth 94 feet
 _____ inches
 _____ inches
 Casing record _____
 Weight per foot _____ Thickness 156
 Diameter From To
6 5/8 inches 8 (+) 1 feet 93 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 93 feet
 Perforations:
 Type perforation sawed
 Size perforation 3/32" x 3" x 6 rows
 From 73 feet to 93 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros. Drilling Contractor
 Address 162 N. Bybee Ln. Yerington, NV Contractor 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada contractor's driller's number issued by the Division of Water Resources 870 & 640
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 640
 Signed Bill Ogden By driller performing actual drilling on site or contractor
 Date 11-19-89

Date started 9-22, 1989
 Date completed 9-30, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 20 Draw down 50 feet 1/2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

89 DEC -8 10 26
 STATE ENGINEERS OF ILL