WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32915
Permit No.
Basin G-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Bailey Construction
MAILING ADDRESS 240 Thomas Jefferson
Reno, Nevada 89509
ADDRESS AT WELL LOCATION 315 Mechanical Dr
Carson City, NV 89704

2. LOCATION NE ¼ ¼ Sec. 32 T. 17 N/S R. 20 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name: Mel Wheeler City

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐ Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	10	10
Blue Clay				
Soft Sand with		10	97	87
Hardpan				
Clay				
Sandy Clay		97	197	150
Medium Hard				
to hard				
D.G. Compact		197	210	13
Semi Hard				
D.G. & Gravel		210	240	30
Clay				
Tree Trunk Coming				
Water				
Major Water				
20 gpm				
T.D. 240				

Date started 12-5, 19 89
Date completed 12-9, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clear water to			
remove mud & fine sand from			
Blew 19-20 GPM from			
230' for 2 hours.			
Air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 9 3/4" inches Total depth 240 feet
..... inches
..... inches
Casing record 6 5/8 Steel
Weight per foot 11.22 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 40 feet to 240 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 1.5"
From 210 feet to 240 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 197 feet below land surface
Flow 19 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name D & H Drilling Co. (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 39795
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Jerry Thomas (By driller performing actual drilling on site or contractor)
Date Dec 12, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627