WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32718
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12766

1. OWNER Bailey Construction
MAILING ADDRESS 2116 Thos Jefferson
Reno, NV

ADDRESS AT WELL LOCATION
1060 Blueline
Carson City, NV 89704

2. LOCATION SW ¼ SE ¼ Sec. 32 T. 17 N/S R. 20 E. Washoe County

PERMIT NO. ~~[illegible]~~ Issued by Water Resources | 52-417-07 Parcel No. | New Washoe City #5 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blow sand		0	9	9
Compacted sand		9	16	7
Cemented gravel w/ clay seams		16	31	15
D.G. Course Medium to Hard, Tight		31	127	96
Contact zone w/ granodiorite 2-4 GPM	✓	127	128	1
Granodiorite, hard, gray to white w/ fractures carrying water major fractures at 155, 167-68 177-79	✓	128	185	57
T.D. 185				

Date started Nov 21, 1989
Date completed Nov 24, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew 15+ GPM from 175' Developed Hours with 452-250 air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/2 to 50 inches Total depth 185 feet
9 7/8 inches
inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	185 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 185 feet

Perforations:
Type perforation 3/32" x 3"
Size perforation Factory Mill Slot
From 100 feet to 185 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 100 feet below land surface
Flow 18+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A + H Pump Co
Contractor
Address Carson City, NV 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Jerald Phennell
By driller performing actual drilling on site or contractor
Date 11/27/89

Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627