

OFFICE USE ONLY
 Log No. 322719
 Permit No. 683
 Basin. I
 NOTICE OF INTENT NO. 13396

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Ruthanne Kurlytis ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 10582 2660 Long Valley Rd
Reno, Nv 89510 Lot 266 - S
 2. LOCATION NW 1/4 NW 1/4 Sec. 15 T 17 N/S R. 21 E Storey County _____
 PERMIT NO. 4-271-40 - Virginia City Highlands
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
White & Brown volcanic rock		0	3	3
Purple, brown white green volcanic rock		3	76	73
Gray white purple volcanic rock - fractured		76	319	243
White black volcanic rock - highly fractured - hard		319	343	24
Brown gray white purple volcanic rock hard		343	391	48
black & white volcanic rock - hard		391	439	48
T.D. 439 feet				

8. 10" - 50 ft WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 439 feet
 Casing record 6 5/8 inches
 Weight per foot 10.78 Thickness .156
 Diameter From To
6 5/8 inches + 1 feet 439 feet
 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 439 feet
 Perforations:
 Type perforation factory - double
 Size perforation 3/32 X 3
 From 399 feet to 419 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 12/15/89, 19____
 Date completed 12/18/89, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 400 feet below land surface
 Flow 30 G.P.M. P.S.I. _____
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L Sparks, Nv
 Contractor 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1509
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 12/18/89 Roger M. Thrall