

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER Sky Ranch Utilities ADDRESS AT WELL LOCATION Spanish Springs
 MAILING ADDRESS _____

2. LOCATION $\frac{1}{4}$ SWSE $\frac{1}{4}$ Sec. 26 T. 21 N/S/R. 20 E Washoe County
 PERMIT NO. 29263 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	4	4
Coarse sand		4	10	6
Sand & clay mix 50%-50% w/s boulders		10	21	11
75% Clay w/s sand		21	63	42
Coarse sand w/s 5% clay		63	79	16
90% w/s sand		79	121	42
Sand w/s 5% clay		121	130	9
Sand w/s 50% clay		130	139	9
90% Clay w/s sand		139	200	61
75% Clay w/s sand		200	362	162
Blue clay w/s 15% sand		362	420	58
Blue & brown clay w/s 15% sand		420	425	5
Brown clay w/s 10% sand		425	465	40
50% Sand & 50% clay		465	492	27
70% Clay & 30% sand		492	575	83
50% Clay & 50% sand		575	644	69
Boulders w/s sand & 10% clay		644	660	16
Fractured blue granite		660	800	140

8. WELL CONSTRUCTION
 Diameter 18 inches Total depth 800 feet
 _____ inches
 _____ inches
 Casing record 12"
 Weight per foot _____ Thickness $\frac{1}{4}$
 Diameter From To
 12" Blank inches +1 feet 199 feet
 12" Luver inches 199 feet 395 feet
 12" Screen inches 395 feet 475 feet
 12" Luver inches 475 feet 575 feet
 12" Screen inches 575 feet 795 feet
 12" Concrete plug 795 feet 800 feet
 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 800 feet
 Perforations:
 Type perforation Rosco Moss shutter screen
 Size perforation .080
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 66 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started '89 10-10, 1989
 Date completed 11-02, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1500	700	143	44

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc
 Contractor
 Address P.O. Box 592 Winnemucca, NV 89445
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada contractor's driller's number issued by the Division of Water Resources C-23
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-27-89

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours