

OFFICE USE ONLY
Log No. 32759
Permit No. _____
Basin 685 Sp. Spring V.
NOTICE OF INTENT NO. 13399

WELL DRILLER'S REPORT
Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Lonny Colby ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 560 Howard Dr Apt B 2200 Piedras
Sparks, Nv 89431 Parcel C of Map 1676

2. LOCATION SE 1/4 SE 1/4 Sec 31 T 21 N/S R 21 E Washoe County _____
PERMIT NO. 76-390-53 - Spanish Springs Valley Ranches Unit 2

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. brown		0	2	2
Blue volcanic rock with some D.G. brown		2	12	10
Black volcanic rock with some brown clay		12	42	30
Multicolored volcanic rock with some brown clay		42	107	65
Black volcanic rock with some green & white volcanic rock		107	117	10
Beige & white volcanic rock with some brown & red volcanic rock		117	192	75
Black brown with some red & green volcanic rock hard		192	278	86
Black brown volcanic rock with some red clay		278	291	13
Red volcanic rock soft		291	312	21
Black red volcanic rock X medium hard		312	338	26

8.10" - 52 ft WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 338 feet

Casing record 6 5/8 inch Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>338</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
Depth of seal 52 feet
Gravel packed: Yes No
Gravel packed from 52 feet to 338 feet

Perforations: factory - double
Type perforation _____
Size perforation 3/32 X 3
From 298 feet to 318 feet
From _____ feet to _____ feet

Date started 11/30/89
Date completed 12/5/89

9. WATER LEVEL
Static water level 300 feet below land surface
Flow 30 G.P.M. _____ P.S.I.
Water temperature cold F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air</u>	<u>no clean</u>	<u>and develop.</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
Date Roger M. Thrall 12/5/89

Plugged by Well log #115896
BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours