

OFFICE USE ONLY  
Log No. 32713  
Permit No. \_\_\_\_\_  
Basin 4-615

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13/51

PRINT OR TYPE ONLY

1. OWNER RICK BARNEY ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS Elko NV 89801

2. LOCATION SE 1/4 NW 1/4 Sec. 26 T 32 N 1/2 R. 57 E Elko County  
PERMIT NO. \_\_\_\_\_  
Issued by Water Resources BK E Lot 9 Parcel No. Pleasant Valley EST Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	4	
Gravel		4	25	
Clay		25	28	
Rocky Gravel		28	80	
Clay Brown		80	89	
Rock		89	200	
Sand & Gravel	Water	200	220	

DEC 29 1989  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
Diameter 10" inches Total depth 220 feet  
Casing record 6" STEEL  
Weight per foot \_\_\_\_\_ Thickness 203  
Diameter From To  
6" inches ±1 feet 220 feet  
Surface seal: Yes  No  Type Cement  
Depth of seal 55 feet  
Gravel packed: Yes  No   
Gravel packed from 55 feet to 220 feet  
Perforations:  
Type perforation slots  
Size perforation 3/16 - 3"  
From 180 feet to 220 feet

9. WATER LEVEL  
Static water level 80 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name AAA Drilling Co Contractor  
Address 355 West River St Contractor  
Nevada contractor's license number issued by the State Contractor's Board 20684  
Nevada contractor's driller's number issued by the Division of Water Resources 904  
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1584  
Signed Shouk C. Juma  
By driller performing actual drilling on site or contractor  
Date 12-11-89

Date started 11-12- 1989  
Date completed 11-19 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
G.P.M. 20 Draw down 80 feet 3 hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours