WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32817
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3569

1. OWNER GENE HARPER
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 3 T. 20S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) LOT-4 (Parcel No.) APN 35-521-20 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	25	25
CALICHIE		25	26	1
CLAY		26	51	25
CALICHIE		51	53	2
CLAY		53	66	13
CALICHIE	T.R.	66	69	3
CLAY		69	75	6
CALICHIE	WB	75	77	2
CLAY		77	88	11
CALICHIE	WB	88	90	2
CLAY		90	94	4
CALICHIE	WB	94	96	2
CLAY		96	103	7
CALICHIE	WB	103	107	4
CLAY		107	112	5
CALICHIE	WB.	112	116	4
CLAY		116	122	6
CALICHIE	WB	122	138	16
CLAY		138	140	2

RECEIVED DEC 1 1989 Water Resources Office - Las Vegas, NV

RECEIVED DEC 1 1989 Div. of Water Resources Branch Office - Las Vegas, NV

Date started 11-20, 1989
Date completed 11-25, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH by 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 feet below land surface
Flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H DRILLING (Contractor)
Address HCR 65 BOX 70906 PAHRUMP NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 11-28-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627