WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32835
Permit No.
Basin 212

NOTICE OF INTENT NO. 3532

PRINT OR TYPE ONLY

1. OWNER John Labounty
MAILING ADDRESS 4420 Arville #25, Las Vegas, NV

ADDRESS AT WELL LOCATION 4090 W. Pebble

2. LOCATION SE ¼ SE ¼ Sec. 18 T. 22 S R. 61 E. Clark County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, cem. gravel		0	20	20
Caliche, alluvium bldrs.		20	40	20
Hard, cemented		40	80	40
Sand, & grav, red clay		80	100	20
Sand & cem. gravel		100	160	60
Clay, cem. grav & sand		160	180	20
Cem. gravel		180	235	55
Sand & unconsolidated grav.		235	260	25
Sand, uncon. grav, red clay		260	280	20
Sand, clay, some gravel		280	300	20
Sand & gravel		300	330	30
Sand, grav, some red clay		330	345	15
Sand & grav. cem. areas		345	375	30
Sand, clay & gravel		375	400	25

RECEIVED
NOV 26 1989
Div. of Water Resources
Branch Office - Las Vegas

Date started October 30, 1989
Date completed November 14, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 3/4 inches Total depth 400 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .156

Diameter	From	To
~~11x8~~ 8 inches	+1 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 400 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½ 8 rows
From 300 feet to 400 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 235 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon, Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 561
Signed Richard R. Thompson (By driller performing actual drilling on site or contractor)
Date November 21, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627