WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32853
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14145

1. OWNER Ken Olsen
MAILING ADDRESS 1060 A341 Gardnerville NV
ADDRESS AT WELL LOCATION 1070 A341 Gardnerville NV
2. LOCATION SE ¼ SW ¼ Sec. 17 T. 12 N S R 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 27-664-18 (Parcel No.) Lambers Field (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ HMD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ boulders to 4"		0	10	10
Pea gravels w/ rock to 2" and sand Surface water @ 40 feet	✓	10	83	73
Pea gravels w/ fine to coarse sand	✓	83	120	37
TD. 120 Ft				

'90 FEB -2 A9:54 STATE ENGINEER'S OFF

Date started Jan 29, 1990
Date completed Jan 31, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Removed drill mud, gravel packed & developed for 2 hours w/ air			
Blowing 30+GPM from 100'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½ to 55 inches Total depth 120 feet
9 3/4 inches
inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 17 feet below land surface
Flow 30+ G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald Phinnell (By driller performing actual drilling on site or contractor)
Date Feb 1, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627