

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 13440

1. OWNER LANCE Jackson EXECUTIVE ENTERPRISES ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAKING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec. 20 T. 12 N. R. 20 E. Dallas County \_\_\_\_\_  
 PERMIT NO. 27401-01 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name MARION ESTATES

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden sand, gravels w/ clay seams</u>		<u>0</u>	<u>9</u>	<u>9</u>
<u>Small gravels w/ sand &amp; soft clay seams</u>		<u>9</u>	<u>10</u>	<u>01</u>
<u>Gravels w/ sand</u>		<u>10</u>	<u>104</u>	<u>34</u>
<u>Tight clayey sand</u>		<u>104</u>	<u>113</u>	<u>9</u>
<u>Coarse sand &amp; gravels carrying water</u>		<u>113</u>	<u>140</u>	<u>27</u>

STATE ENGINEER'S OFFICE  
 T.D. 11/11  
 OK 11/11

Date started 11/11/90  
 Date completed 11/11/90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Flushed w/ water to remove mud &amp; get real pack developed with air 35-40 gpm from</u>			<u>ft</u>

BAILER TEST

G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION

Diameter 93/4 inches Total depth 140 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 5/8" steel  
 Weight per foot 11.7 Thickness 1.56  
 Diameter From To  
6 5/8 inches +2 feet 140 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type concrete  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation factory Mill slot  
 Size perforation 3/32" x 3"  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 27 feet below land surface  
 Flow 35+ G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & A Pump Co Contractor  
 Address Carron City, NV 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 13295  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1535  
 Signed Jerald Phennell  
 By driller performing actual drilling on site or contractor  
 Date Jan 12, 1990