WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. B2856
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12746

1. OWNER Dennis Clark
MAILING ADDRESS PO. Box 1182
Minden NV. 89423

ADDRESS AT WELL LOCATION 1124 Meadowlark
Minden NV.

2. LOCATION NE ¼ SO ¼ Sec. 20 T. 12 N/S R. 20 E DOUGLAS County
PERMIT NO. (Issued by Water Resources) 27-730-12 (Parcel No.) Country lane (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1'	1'
River boulders & clay		1	18'	17'
Boulders and gravel		18	100	82'
Gravels		100	110	10'
Boulders		110	125	15'
Gravels		125	149	24'
Boulders cemented w/clay		149	154	5'
Gravels		154	172	18'
Boulders		172	180	6'

'90 JUN 10 A9:14
STATE ENGINEERS OFFICE

Date started 12/18, 19 89
Date completed 12/30, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	60 +		2

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 180' feet
inches
inches
Casing record 180' steele
Weight per foot 8 lbs Thickness 188

Diameter	From	To
8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type cement
Depth of seal 58' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 180 feet to 58 feet

Perforations:
Type perforation Factory
Size perforation 3/32 X 3
From 180 feet to 160 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 29' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rawehack Drilling Inc. (Contractor)
Address 2668 Fuller Ave Minden NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada contractor's driller's number issued by the Division of Water Resources 1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/8/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627