WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32867
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14144

1. OWNER J+D Construction
MAILING ADDRESS 1630 Porter Lane Minden, Nevada 89423
ADDRESS AT WELL LOCATION 2609 Gordon St. Minden, Nevada 89423

2. LOCATION SE ¼ SW ¼ Sec. 34 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 21-203-14 (Parcel No.) Johnson Lane (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Oven Burden Blow Sand		0	5	5
Medium fine to fine sand with Clay lenses		5	5	90
Tight heavy grey clay		90	96	6
Sand, Course, w/Clay		96	107	11
Gravels, fine to course w/ Sand & water	✓	107	128	21
Tight, yellow Clay		128	130	2
Note: 5 ft blank on bottom Filled blank w/gravel				
T.D. 130 Ft				

Date started 10-25, 1990
Date completed 1-26, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clean water to gravel pack. Developed with air for 3 Hours Blew GPM from 80-100'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/2 inches 55 inches 7 3/4 inches ..... inches
Total depth 130 feet
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .136

Diameter	From	To
6 5/8 inches	2 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 130 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 105 feet to 125 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 46 feet below land surface
Flow 25+ G.P.M. ..... P.S.I.
Water temperature 60.1 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co (Contractor)
Address Carson City NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] By driller performing actual drilling on site or contractor
Date Jan 29, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627