WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32875
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13439

1. OWNER Don Horton
MAILING ADDRESS 253 Sam Clemens Dayton, Nevada
ADDRESS AT WELL LOCATION 267 Sam Clemens Dayton, Nevada
2. LOCATION NE ¼ NW ¼ Sec. 28 T. 17 N S R. 22 E Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. | Mark Twain Estates Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	5	5
Cemented gravels, tan to dark, medium to hard drilling		5	280	275
Major water at 267-273	✓			
T.D. 280				

'90 JAN -9 A9:00
RECEIVED
STATE ENGINEERS OFFICE

Date started 12/21, 1989
Date completed 12/27, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Gravel packed & developed with 250-450 air			
Blowing 10 GPM from 260 ft			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/2 to 60 inches Total depth 280 feet
9 3/4 inches
inches
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	280 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 260 feet to 280 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 240 feet below land surface
Flow 10 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 21472
Signed [signature] By driller performing actual drilling on site or contractor
Date Nov 28, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (Q) 627