

OFFICE USE ONLY  
 Log No. 32883  
 Permit No. \_\_\_\_\_  
 Basin. 6-87  
 NOTICE OF INTENT NO. 13038

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER John Pagni ADDRESS AT WELL LOCATION 2400 East Prater Way  
 MAILING ADDRESS 2400 East Prater Way  
Sparks, Nv 89434

2. LOCATION SE 1/4 NE 1/4 Sec. 2 T. 19 N/S R. 20 F. Washoe County  
 PERMIT NO. 30-020-73 -

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic cobbles & brown sand		0	5	5
Sands gravels with some cobbles		5	35	30
Green gravels		35	52	17
Brown fractured rock		52	70	18
Hard brown green rock		70	77	7
Brown & green fractured rock		77	104	27
Red volcanic sands & gravels		104	154	50
Yellow & red clay with Red & green gravels		154	190	36
Hard fractured volcanic rock green & brown		190	205	15
Red & brown clay with green brown & red gravels		205	218	13
Yellow clay with green red & yellow brown gravel		218	235	17
Sticky yellow & brown clay		235	272	37
Fractured brown & green some red rock		272	299	27
T.D. 299 ft.				

8. 10" - 60' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 299 feet

Casing record 6 5/8 inch Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1 1/2</u> feet	<u>299</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 54 feet  
 Gravel packed: Yes  No   
 Gravel packed from 54 feet to 299 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 271 feet to 291 feet  
 From 151 feet to 171 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1/5/90, 19\_\_\_\_  
 Date completed 1/10/90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 64 feet below land surface  
 Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc  
 Address 625 Spice Islands Dr Suite L Sparks, Nv  
 Contractor 89431

Nevada contractor's license number 15291  
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources

Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor

Date Roger M. Thrall 1/16/90