WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32888
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13863

1. OWNER DOUG SMITH
MAILING ADDRESS 1780 BELL AIRE LANE
FALLON, NV 89406

ADDRESS AT WELL LOCATION RENO HWY
FALLON, NV 89406

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 19 N/S R. 28 E CHURCHILL County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	16	16
CLAY		16	23	7
SAND	X	23	31	8
CLAY		31	36	5
GRAVEL	X	36	48	12
GRAY SILT & CLAY		48	81	33
CLAY		81	84	3
GRAVEL & SAND	X	84	96	12
CLAY		96	116	20
SAND & CLAY STREAKS		116	149	33
CLAY		149	162	13
SAND	X	162	171	9
CLAY		171	180	9
GRAVEL	X	180	182	2

Date started 1-6, 19 90
Date completed 1-8, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN @ 65 GPM			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 192 feet
____ inches
____ inches
Casing record 6 5/8" X 192
Weight per foot 12.9 Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	192 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32 X 3
From 185 feet to 190 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 18 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature 65 °F Quality UNKWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 FALLON, NV 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JANUARY 16, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627