WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 32919
Permit No.
Basin CL-49

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12958

1. OWNER City of Carlin
MAILING ADDRESS PO Box 785 Carlin, NV
ADDRESS AT WELL LOCATION CW 3 Sewer Treatment Facilities

2. LOCATION NW ¼ NW ¼ Sec. 35 T. 33 (N) S R. 52 E. Elko County
PERMIT NO. M/O-206 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clayey SILT | | 0 | 6.5 | 6.5 |
| Silty Sandy GRAVEL | | 6.5 | 14 | 7.5 |
| Silty SAND | | 14 | 19.5 | 5.5 |

RECEIVED JAN 29 1991 STATE ENGINEER

Date started December 20, 1990
Date completed " " , 19 "

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 2 inches Total depth 19.5 feet
..... inches
..... inches
Casing record 2" PVC
Weight per foot ..... Thickness Sch 40

| Diameter | From | To |
|---|---|---|
| 2" Blank inches | 0 feet | 4½ feet |
| 2" Perf inches | 4½ feet | 14½ feet |
| 2" Blank inches | 14½ feet | 19½ feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement & Bentonite
Depth of seal 3 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 3 feet to 19½ feet

Perforations:
Type perforation PVC Sch 40 Slot
Size perforation 0.010"
From 4½ feet to 14½ feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 5.9 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [illegible] Contractor
Address 1635 [illegible] RD RENO NEV 89502 Contractor
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [illegible] By driller performing actual drilling on site or contractor
Date 1/18/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627