WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32920
Permit No.
Basin 4-51

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2908

1. OWNER City of Carlin
MAILING ADDRESS P.O. Box 785
Carlin, Nevada

ADDRESS AT WELL LOCATION OW 4 Sewer Treatment Facilities.

2. LOCATION S.W. ¼ S.W. ¼ Sec. 26 T. 33 N/S R. 52 E. County

PERMIT NO. M/O-206 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt		0	2.6	2.6
Clayey Silt		2.6	6.9	4.3
Silty Sandy Gravel		6.9	12.5	5.6
Gravelly Sand		12.5	13.5	1.0
Sandy Gravel		13.5	14.7	1.2
Silty Sand		14.7	19.5	4.8

'90 JAN 29 AM 10:55
STATE HIGHWAY

Date started December 20, 1989
Date completed " " , 19 11

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 2 inches Total depth 19½ feet
..... inches
..... inches
Casing record 2" PVC
Weight per foot ..... Thickness Sch. 40

Diameter	From	To
2" Blank inches	0 feet	4½ feet
2" Perf inches	4½ feet	14½ feet
2" Blank inches	14½ feet	19½ feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement + Bentonite / Concrete Cap
Depth of seal 3 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 3 feet to 19½ feet

Perforations:
Type perforation PVC Sch. 40 Slot.
Size perforation 0.010
From 4½ feet to 14½ feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 8.1 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address 1635 Belford Rd. Reno Nev. 89502 Contractor
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller N28
Signed [signature] By driller performing actual drilling on site or contractor
Date 1/19/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627