WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32935
Permit No. 54212T
Basin 4-61

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13541

1. OWNER Barrick Goldstrike Mine
MAILING ADDRESS P.O. Box 29
Elko, Nevada 89801

ADDRESS AT WELL LOCATION
PPW7

2. LOCATION NW ¼ SE ¼ Sec. 19 T 36 N/S R 50 E Eureka County
PERMIT NO. 54212T (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
rock & clay		0	20	20
rock some clay		20	60	40
brown clay		60	70	10
gray clay & rock layers		70	101	31
gray rock & clay		101	175	74
gray rock		175	218	43
gray rock very little clay		218	250	32
gray rock		250	285	35
clay w/some gray rock		285	287	2
gray clay		287	335	48
gray clay & rock		335	350	15
gray rock some clay		350	365	15
gray rock, clay & sandstone		365	390	25
clay & rock		390	475	85
white & gray clay little rock		475	500	25

STATE ENGINEER '90 JAN 16

Date started December 18, 19 89
Date completed January 8, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	15	203	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 500 feet
..... inches
..... inches
Casing record 14" x .250
Weight per foot 36.71 Thickness

Diameter	From	To
14 inches	+2 feet	500 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 500 feet

Perforations:
Type perforation R/M shutter screen
Size perforation .250 wall
From 130 feet to 490 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 124 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address P.O. Box 2646, Elko, Nevada 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1493
Signed [signature] (By driller performing actual drilling on site or contractor)
Date January 11, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627