WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32960
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3686

1. OWNER VirgEL BOWEN
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SE ¼ Sec. 25 T. 19 S N/S R. 52 E NYE County
PERMIT NO. (Issued by Water Resources) LOT 9 (Parcel No.) UNIT 4 BLOCK 1 BELL VISTA SUBDIVISION (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	13	13
CALICHIE		13	14	1
CLAY		14	25	11
CALICHIE		25	26	1
CLAY		26	52	26
CALICHIE	WB	52	53	1
CLAY		53	56	3
CALICHIE	WB	56	57	1
CLAY		57	67	10
CALICHIE	WB	67	69	2
CLAY		69	98	9
CALICHIE	WB	78	81	3
CLAY		81	85	4
CALICHIE	W.B	85	86	1
CLAY		86	98	12
CALICHIE	W.B	98	100	2
CLAY		100	112	12
CALICHIE	W.B	112	114	2
CLAY		114	116	2
CALICHIE	WB	116	117	1
CLAY		117	120	3
CALICHIE	W.B	120	122	2
CLAY		122	134	12
CALICHIE	WB	134	135	1
CLAY		135	140	5

Date started 3-16, 1990
Date completed 3-21, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
APR 04 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140' 8 5/8
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAWCUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 47 feet below land surface
Flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H Drilling (Contractor)
Address HCR 65 BOX 80358 PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
Signed (By driller performing actual drilling on site or contractor)
Date 4-2-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627