WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32981
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3554

1. OWNER NAT. CONVENIENCE STORES
MAILING ADDRESS 100 WAUGH DR
HOUSTON TX
ADDRESS AT WELL LOCATION MW-3
C/O NTMRC CORP

2. LOCATION NW ¼ NE ¼ Sec. 29 T. 21 N(S) R. 62 E. CLARK County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑ (MONITOR)
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND W/ GRAV		0	4'	4'
CLAYEY SILT		4'	8'	4'
SILTY SAND		8'	12'	4'
CLAYEY SILT		12'	26'	14'

Date started 10-24-89, 19 89
Date completed 10-24, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
N/A			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 4" inches Total depth 26' feet
____ inches
____ inches
Casing record SURFACE TO 26'
Weight per foot ____ Thickness SCH 40 PVC

Diameter	From	To
4" inches	0 feet	26 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type PORTLAND CEMENT
Depth of seal 18' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 2' feet to 26' feet

Perforations:
Type perforation FACTORY SLOTTED SCREEN
Size perforation 0.020"
From 4.5 feet to 26 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 10.98' feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON / CONVERSE CONSULTANTS (Contractor)
Address 4070 S POLARIS LAS VEGAS NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board ____
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-24-89

RECEIVED NOV 21 1989 Div. of Water Resources Western Office - Las Vegas, NV

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627