

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 13949

PRINT OR TYPE ONLY

1. OWNER Harold & Denise Watkins ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 615 Hwy 395 N 3190 Churchill  
Carson City, Nv 89704 Lot 1 Block Q  
 2. LOCATION NE 1/4 NE 1/4 Sec 6 T. 16 N/S R. 20 E Washoe County \_\_\_\_\_  
 PERMIT NO. 050-425-04 New Washoe Farms  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown yellow white D.G. sands		0	25	25
Brown clay with some sands		25	78	53
Sticky tan clay		78	83	5
Fractured granite		83	115	32
Tan clay tan yellow white sands		115	139	24
T.D. 139 ft				

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 139 feet

Casing record 6 5/8 inch  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1 1/2</u> feet	<u>139</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type neat cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 139 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 99 feet to 119 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2/1/90, 19\_\_\_\_  
 Date completed 2/2/90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 50 feet below land surface  
 Flow 10 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc.  
Contractor  
 Address 625 Spice Islands Dr Suite L Sparks, Nv  
Contractor 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources the on-site driller  
 Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 2/5/90