WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33080
Permit No.
Basin 7-97 Honey Lake V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13656

1. OWNER Washoe County
MAILING ADDRESS P.O. Box 11130
Reno, NV 89520

ADDRESS AT WELL LOCATION Aspen Pass
Monitor Well #2

2. LOCATION NW ¼ NE ¼ Sec. 23 T 27 N/S R. 19 E Washoe County
PERMIT NO. W-315 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitor
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	15	15
Sand & gravel		15	23	8
Green clay		23	50	27
Blue clay		50	78	28
Sand & gravel		78	100	22
Sand & gravel w/s clay stringers		100	136	36
Fractured bisalt		136	144	8
Clay w/s sand stringers		144	154	10
Clay		154	220	66
Sand & gravel w/s clay		220	234	14
Fractured bisalt (hard)		234	410	176

Date started February 4, 19 90
Date completed February 8, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 470 feet
inches
inches
Casing record 2"
Weight per foot ..... Thickness SCH 40

Diameter	From	To
2" Steel Blank	0 feet	260 feet
2" Steel Mill Slot	260 feet	470 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 225 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 255 feet to 470 feet

Perforations:
Type perforation Single Standard
Size perforation 1/8 X 3
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 35' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 592 Winca., NV 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada contractor's driller's number issued by the Division of Water Resources C-23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-21-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627