WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33044
Permit No.
Basin 4-419

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER REED BRINKERHOFF
MAILING ADDRESS 336-13 Osino
Elko, ~~NV~~ 89801

ADDRESS AT WELL LOCATION Lot 2, Blk 10
Meadow Valley Ranchos Unit #3

2. LOCATION SW ¼ NE ¼ Sec. 3 T. 35 N/S R. 56 E. Elko County
PERMIT NO. Issued by Water Resources | Lot 2, Blk 10 Parcel No. 35-010-02-4 | Meadow Valley Ranchos Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil (sandy loam)		0	2	2
Caliche		2	4	2
Alluvium - clay, sand & gravel		4	42	38
Gravel		42	44	2
Clay & gravel		44	55	11
	Seep		55	
Clay, sand, gravel		55	74	19
Gravel (cemented)	4gpm	74	75	1
Clay		75	131	56
Gravel	5gpm	131	132	1
Clay & gravel		132	165	33
Sand (coarse)	✓✓✓	165	175	10
Clay		175	180	
T.D. 180				

Date started 2/2, 1990
Date completed 2/10, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 52 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter ~~6 5/8~~ inches Total depth 180 feet
10" inches to 55
8" inches
Casing record 181.5 ft. steel
Weight per foot 13.92 Thickness .203

Diameter	From	To
6 5/8 inches	+ 1.5 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to T.D. feet

Perforations:
Type perforation Torch cut
Size perforation 1/8" x 4"
From 123 feet to 175 feet
From 66 feet to 87 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 48 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING Co
Contractor
Address 203 PINE ST. 89801
Contractor
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada contractor's driller's number issued by the Division of Water Resources 632
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth
By driller performing actual drilling on site or contractor
Date 2/10/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627