

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 3941

Billy J. Strickland
 1. OWNER Earl Norman Selbach ADDRESS AT WELL LOCATION _____

MAILING ADDRESS Rt. Box 445
Amargosa Valley, Nevada 89020

2. LOCATION SE 1/4 NE 1/4 Sec. 16 T. 16 S. N/S R. 48 E Nye County

PERMIT NO. 53189 66445
 taken from # 16562 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. CERTIFIED TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	42	42
Sand & Gravel		42	52	10
Sandy Clay		52	73	21
Rocks & Sand		73	96	26
Clay		96	102	6
Sand & Gravel	X	102	142	40
Broken Sand Stone	X	142	168	26
Sand & Gravel	X	168	180	12
Brown Clay		180	190	10

8. WELL CONSTRUCTION

Diameter 1.4 inches Total depth 190 feet
 _____ inches
 _____ inches
 Casing record 190 ft of 10 in casing
 Weight per foot 18 lbs. Thickness 188

Diameter	From	To
<u>1.4</u> inches	<u>0</u> feet	<u>190</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 190 feet
 Perforations:
 Type perforation Factory Cut
 Size perforation 3/16
 From 143 feet to 190 feet
 From _____ feet to _____ feet

RECEIVED
 05 MAY 19 9 35 AM
 STATE ENGINEERS OFFICE

RECEIVED

FEB 1 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started January 15, 1990
 Date completed January 25, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 20 gals Draw down 0 feet 1/4 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 106 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address St. Rt. Box 36525 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed _____ By driller performing actual drilling on site or contractor
 Date January 27, 1990

