

OFFICE USE ONLY  
 Log No. 53056  
 Permit No. 23184  
 Basin 10-121a

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 10802

PRINT OR TYPE ONLY

1. OWNER CORONA GOLD INC. ADDRESS AT WELL LOCATION  
 MAILING ADDRESS P.O. BOX 3220 SANTA FE MINE  
HAWTHORNE, NEVADA 89415 NORTHEAST LUNING

2. LOCATION NW 1/4 NW 1/4 Sec. 3 T. 8 N. R. 34 E. MINERAL County  
 PERMIT NO. 53187 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Industrial   
 Municipal  Test  Stock

PW #4  
 Cable  Rotary  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Course sand, gravel & clay		0	100	100
Large gravel, sand & clay		100	160	60
Sand & clay		160	900	740
Fine gravel, sand & Clay		900	940	40
Clay & sand		940	1000	60
Fine gravel & clay mix		1000	1040	40
White & borwn sitcky clay with broken rock		1040	1100	60
Broken rock		1100	1117	17

8. WELL CONSTRUCTION  
 Diameter 17-1/2 inches Total depth 1117 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 12-3/4 inch O.D. x .250 inch wall  
 Weight per foot #33.38 Thickness \_\_\_\_\_  
 Diameter From To  
12-3/4 inches \_\_\_\_\_ +1 feet 1117 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

Surface seal: Yes  No  Type cement sand grout  
 Depth of seal 57 feet  
 Gravel packed: Yes  No   
 Gravel packed from 57 feet to 1117 feet  
 Wadsworth 3/8 inch minus well rock  
 Perforations: 12-3/4 inch O.D. x .250 wall Roscoe Mos  
 Full flo shutter screen mild steel  
 Type perforation louvers 1/8 inch x 1 inch  
 Size perforation \_\_\_\_\_  
 From 844 feet to 1114 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started November 20, 1989  
 Date completed January 8, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 825 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CHAS. SARGENT IRRIGATION INC.  
 Contractor  
 Address 9955 NORTH VIRGINA STREET, RENO, NV. 89506  
 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada contractor's driller's number issued by the Division of Water Resources 1391  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1578  
 Signed Larry McCracken  
 By driller performing actual drilling on site or contractor  
 Date February 27, 1990