WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 3307-0
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14149

1. OWNER Charles & Sharon Ray
MAILING ADDRESS Rte 1 Box x Waterloo Ln Gardnerville, Nevada 89410
ADDRESS AT WELL LOCATION 1276 Jones Ranch Road Gardnerville, NV 89410

2. LOCATION SE ¼ SW ¼ Sec. 3 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 19-390-04 (Parcel No.) None (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden & fill Material w/ sand		0	7	7
Sand, N.G w/ Clay seams		7	83	76
Gravels with sand & fine Clay seams	✓	76	112	36
Course gravels w/ fine to Course sand	✓	112	140	28
T.D. 140				

Date started Feb 19, 1990
Date completed Feb 19, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to remove drill mud & gravel pack			
Blew	40+ GPM	from 100 ft	
with air for	2 hrs		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 3/4 inches Total depth 140 feet
9 3/4 inches
inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 140 feet

Perforations:
Type perforation Factory Mill Slotted
Size perforation 3/32" x 3"
From 120 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 18 feet below land surface
Flow 40+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Feb 20, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627