...SION OF WATER RESOURCES
...IENT'S COPY
...LL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33076
Permit No.
Basin 8-105

PRINT OR TYPE ONLY (Ann Burcham) Project

NOTICE OF INTENT NO. 14155

1. OWNER Pete Rosgen Const
MAILING ADDRESS P.O. Box 229
GENOA, Nevada
ADDRESS AT WELL LOCATION 2149 Fish Springs Road
Gardnerville, Nv

2. LOCATION SW ¼ NE ¼ Sec. 6 T. 12 N R. 21 E Douglas County

PERMIT NO. None (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, dirt + boulders		0	5	5
Boulders + Sand w/ Clay		5	19	14
Clayey Sand		19	20	1
Boulders + gravels w/ sandy Clay		20	26	6
Clay, loose		26	37	11
Clay w/ small gravels + sand		37	50	13
Cemented boulders		50	55	5
Clays w/ Sand		55	79	24
Pea gravels w/ Sandy Clay		79	97	18
Tight Clays		97	137	40

Date started March 3, 19 90
Date completed March 6, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clean water to remove drill Mud.			
Blew with air to develop			
Blewing 40 GPM for 2 Hrs			
from 140'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/4" inches Total depth 155 feet
9 7/8" inches
inches
Casing record 6 5/8" steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	72 feet	155 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐, Type Concrete
Depth of seal 60' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 155 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" & 3"
From 135 feet to 155 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow 40+ G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co (Contractor)
Address Carson City, Nv 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald Phinnell (By driller performing actual drilling on site or contractor)
Date 3/8/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

Page 2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33076
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

page #2

NOTICE OF INTENT NO. 14155

1. OWNER Pete Rogney (Cam Burchan)
MAILING ADDRESS P.O. Box 229
Genoa, Nevada

ADDRESS AT WELL LOCATION
2149 Fish Spgs Road
Gardnerville, Nevada

2. LOCATION SW ¼ NE ¼ Sec. 6 T. 12 N S R. 21 E. Douglas County

PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Med sands w/gravels	✓	137	154	17
Clay, tight		154	155	1
T.D. 155'				

'90 MAR 13 A9:15
STATE ENGINEERS OFF

Date started March 3, 1990
Date completed March 6, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 9 7/8 inches Total depth 155 feet
..... inches
..... inches
Casing record 6 5/8 steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	155 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type .....
Depth of seal 60' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 155 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation .....
From 135 feet to 155 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow 40+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address Carson City, NV 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald Phinnell
By driller performing actual drilling on site or contractor
Date 3/8/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627