WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33098
Permit No.
Basin 10-179

bac

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11742

1. OWNER Cecil Weaver
MAILING ADDRESS Sr 1 Box 5 Ely NV 89301
ADDRESS AT WELL LOCATION Parcel no. 134 Cross Timbers Sub.

2. LOCATION SE ¼ NW ¼ Sec. 22 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) | Parcel No. 134 | Subdivision Name Cross timbers Subdivison

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	
Lime-gravel con.		2	3	
hard clay		3	7	
Clay		7	12	
gravel conglomerate		12	29	
Clay		29	32	
gravel-clay con.		32	48	
gravel con.		48	67	
Sandy clay con.		67	74	
gravel	water	74	75	1
Clay		75	81	
gravel	water	81	82	1
Clay		82	92	
gravel	water	92	93	1
Sandy Clay		93	120	
gravel	water	120	121	1
Sandy Clay		121	146	
gravel	water	146	147	1
Sandy Clay		147	150	

Date started March 7, 1990
Date completed March 19, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 10 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 5/8 inches Total depth 150 feet
inches
inches
Casing record 151
Weight per foot 12 Thickness 3/16

Diameter	From	To
10 inches	0 feet	50 feet
8 inches	50 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete grout
Depth of seal 3 to 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation mill
Size perforation ⅝ x 2 x 6 row
From 90 feet to 110 feet
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 74 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada contractor's driller's number issued by the Division of Water Resources 1538
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvan Maynard (By driller performing actual drilling on site or contractor)
Date March 19 - 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627