WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 33107
Permit No.
Basin 6-87

# WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 12910

1. OWNER Airport Authority of Washoe Co.
MAILING ADDRESS P.O. Box 12490
Reno, NV 89510

ADDRESS AT WELL LOCATION Fire Station No. 1
Reno Cannon International Airport

2. LOCATION SE ¼ NE ¼ Sec. 19 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. M/O 235 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Concrete | | 0 | 0.5 | 0.5 |
| Baserock | | 0.5 | 3 | 2.5 |
| Sandy Clay | | 3.0 | 4.5 | 1.5 |
| Clayey Silt | | 4.5 | 8 | 3.5 |
| Clayey Sand | | 8 | 11.5 | 3.5 |
| Silty Sand | X | 11.5 | 14 | 2.5 |
| Sand | X | 14 | 20 | 6 |

'90 MAR 26 P12:56
RECEIVED
STATE ENGINEERS OFFICE

Date started January 30, 1990
Date completed January 30, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 4 inches Total depth 20 feet
inches
inches
Casing record
Weight per foot Thickness

| Diameter | From | To |
|---|---|---|
| 4 inches | 0 feet | 4.5 feet |
| 4 inches | 19.5 feet | 20 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type neat cement + bentonite
Depth of seal 3.5 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 3.5 feet to 20 feet

Perforations:
Type perforation factory - slotted
Size perforation 0.020 in.
From 4.5 feet to 19.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 4.98 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address 1635 Belford RD RENO NEV 89509 Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/5/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627