WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33119
Permit No. 51559
Basin 4-86

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3166

1. OWNER L.C.S. &W. #2
MAILING ADDRESS Box 144
Austin, NV

ADDRESS AT WELL LOCATION 1 mile East of
Austin

2. LOCATION SE ¼ NE ¼ Sec. 29 T. 19 N/S R. 44 E Lander County
PERMIT NO. 51559 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed granite		0	12	12
" gra. dark brn		12	40	28
Blue gray granit hard		40	125	85
lge gouge fault	--	125	140	15
Blue granit hard		140	225	85
Fracture little water -		225	230	5
Blue granit hard		230	250	20
" some small fracture		250	272	22
Granite faulty	--	272	385	113
Blue granite		385	415	30
			T.D.	

'90 APR 10 AM 1 29
STATE ENGINEERS OFFICE

Date started 3-3, 1989
Date completed 3-14, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air lifted app. 30 G.P.M.			

BAILER TEST
G.P.M. -- Draw down -- feet -- hours
G.P.M. -- Draw down -- feet -- hours
G.P.M. -- Draw down -- feet -- hours

8. WELL CONSTRUCTION
Diameter hole 8 3/4 inches Total depth 415 feet
Casing record steel
Weight per foot ____ Thickness .188

Diameter	From	To
inches	-1' feet	75 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type neat cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 415 feet

Perforations:
Type perforation sawed
Size perforation 1/8 X 2
From 75 feet to 255 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 62' feet below land surface
Flow none G.P.M. -- P.S.I.
Water temperature cold ° F. Quality poor stinks

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Potter Drilling Co (Contractor)
Address P.O. Box 1815, Fallon, NV (Contractor)
Nevada contractor's license number 20161
Nevada contractor's drillers number 1348
Nevada driller's license number 1348 (Actual Driller)
Signed Jim Potter (Contractor)
Date 4-9-90

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434