

OFFICE USE ONLY  
 Log No. 33128  
 Permit No. \_\_\_\_\_  
 Basin 6-89 Washoe Springs V

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

25 DCD

NOTICE OF INTENT NO. 13739

1. OWNER DON BROWN ADDRESS AT WELL LOCATION 5065 Axehandle Road  
 MAILING ADDRESS 618 Valle Vista Ave. Reno, NV 89510  
Vallejo, CA 94590

2. LOCATION SW 1/4 SE 1/4 Sec. 25 T. 22N N/S R. 20 E Washoe County  
 PERMIT NO. 55413 076-162-10 Palomino Valley Unit 5 25-2-0-9  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Loose brown sand		2	16	14
Decomposed granite		16	63	47
Soft zone (NO WATER)		63	67	4
D.G.		67	106	39
Soft zone (NO WATER)		106	111	5
D.G.		111	125	14
Soft zone med D.G.	X	125	130	5
D.G.		130	151	21
Soft zone coarse D.G.	X	151	157	6
D.G.		157	160	3

90 MAR 20 10:42  
 RECEIVED  
 STATE ENGINEERS OFFICE

N59 789789  
 W 11 692019 NMD27

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 160 feet

Casing record 160' steel casing installed.  
 Weight per foot \_\_\_\_\_ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 160 feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 3 x 5 around  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-13-90  
 Date completed 3-15-90

9. WATER LEVEL  
 Static water level 104 feet below land surface  
 Flow 30G.P.M. P.S.I.  
 Water temperature cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne DRilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number 22549 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Wayne Drilling By driller performing actual drilling on site or contractor  
 Date March 15, 1990

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours