WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33166
Permit No.
Basin 21-47A

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13764

1. OWNER ROYCE L. HACKWORTH
MAILING ADDRESS 1031 Dotta Drive
Elko, NV 89801

ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 35 N/S R. 56 E. Elko County
PERMIT NO. (Issued by Water Resources) Lot 1 Blk 41 (Parcel No.) Unit 3 Meadow Valley Ranchos (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	18	18
Fine to med. gravel		18	40	22
Clay & fine gravel		40	80	40
Med. to fine gravel and clay		80	220	140
Course gravel		220	225	5
Fine to med. gravel w/streaks of clay		225	280	55
Med. to course gravel		280	298	18

First water at 110' more water at 285

RECEIVED MAR 28 '90 10:16 STATE ENGINEER'S OFFICE

Date started February 12, 1990
Date completed February 15, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	35		Blow Test

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 298 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness

Diameter	From	To
6" inches	+2 feet	-278 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 0 to 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 298 feet

Perforations:
Type perforation Machine slots
Size perforation 1/8" x 3"
From -278 feet to -298 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 105 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1166
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-23-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627