

OFFICE USE ONLY  
 Log No. 33219  
 Permit No. \_\_\_\_\_  
 Basin B-105

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 14072

PRINT OR TYPE ONLY

1. OWNER Kirk Johnson ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO BOX 2435  
GARD. NV 89423  
 2. LOCATION SE 1/4 SE 1/4 Sec. 21 T. 12 N/S R. 20 E Douglas County  
 PERMIT NO. 29-101-06 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name Rubenstein

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAVEL & SAND		0	10	
GRAVEL		10	25	
CLAY SAND & GRAVEL		25	90	
CLAY GRAVEL & ROCKS		90	95	
CLAY GRAVEL & SAND		95	120	
CLAY SAND & ROCKS		120	130	
SAND GRAVEL & ROCK	X	130	165	
SAND & GRAVEL	X	165	175	
SAND GRAVEL & ROCK	X	175	190	
SAND & GRAVEL	X	190	200	
SAND GRAVEL & ROCK	X	200	230	
GRAVEL & ROCK	XX	230	240	

RECEIVED  
 APR 30 1990  
 STATE ENGINEERS OF NV

Date started 4-2 19 90  
 Date completed 4-3 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>112</u>	<u>20+</u>		<u>2hrs</u>

BAILER TEST

G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 240 feet  
 Casing record DATA A-53-0 6 5/8" X 20' X .156"  
 Weight per foot Spl Thickness 156  

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>240</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 240 feet to 50 feet  
 Perforations:  
 Type perforation Factory Perf.  
 Size perforation 3" X 5/32"  
 From 240 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 123 feet below land surface  
 Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Richard Peeling, Inc. Contractor  
 Address 2668 Fuller Minden NV 89423 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board #021268  
 Nevada contractor's driller's number issued by the Division of Water Resources #7390  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 4-6-90