WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33244
Permit No.
Basin G-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14489

1. OWNER Young Enterprizes, Inc
MAILING ADDRESS BOX 18196
Reno, Nevada 89511

ADDRESS AT WELL LOCATION Map 2024
50 Darylin Lane
Carson City, NV 89704

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. WCty 003810 (Issued by Water Resources) Parcel No. New Washoe City (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blow sand		0	7	7
Sand, loose		7	30	23
Clay seam, tight		30	34	4
Sand, loose		34	95	61
Clay seam		95	110	15
D.G. Sand w/ fines		110	135	25
D.G. Sand, course		135	140	5

NOTE: 10 Foot blank on bottom of string filled with pea gravel to stop sand from coming in bottom.

T.D. 140'

Date started April 17, 1990
Date completed April 18, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed drill mud with clean water & gravel packed developed with air & water making 30 gpm from 110' with 250-450 air for 2 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½ inches Total depth 140 feet
..... inches
..... inches
Casing record 6 5/8 steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 65 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 65 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 110 feet to 130 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 7 feet below land surface
Flow 30+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joel B. Butler (By driller performing actual drilling on site or contractor)
Date April 18, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627